

COMMONWEALTH OF KENTUCKY

BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF HENDRON WATER )  
DISTRICT FOR A PERMANENT DEVIATION )  
FROM 807 KAR 5:066, SECTION 5(4), ) CASE NO. 89-114  
REGARDING WATER STORAGE )

O R D E R

By application received May 4, 1989, Hendron Water District ("Hendron Water") requested a deviation from 807 KAR 5:066, Section 5(4), which requires a utility to provide water storage to ensure a minimum of 1 day's supply of its average daily water usage.

The Commission, having reviewed the evidence of record and being advised, is of the opinion and finds that:

1. Hendron Water's current water storage capacity is 250,000 gallons.

2. Hendron Water's average daily water usage is 401,000 gallons.

3. Hendron Water does not provide water service to any critical health facilities.

4. Hendron Water does not produce any water, but purchases its water from the city of Paducah.

5. Hendron Water's current water storage facilities are not deemed adequate and are therefore in violation of 807 KAR 5:066, Section 5(4).

6. Hendron Water is in the planning stages on improvement projects for its water distribution system. One of those projects includes the construction of a 300,000-gallon water storage tank.

7. Because of the time needed to plan, finance and implement a program to construct water storage facilities, Hendron Water should be given until June 1, 1992 to bring it within compliance of the Commission's water storage requirements.

IT IS THEREFORE ORDERED that:


1. Hendron Water be and it hereby is given until June 1, 1992 to comply with the provisions of 807 KAR 5:066, Section 5(4).

2. Hendron Water shall take all necessary actions to bring its water storage facilities within compliance of the Commission regulations prior to June 1, 1992.

Done at Frankfort, Kentucky, this 19th day of May, 1989.

PUBLIC SERVICE COMMISSION

  
\_\_\_\_\_  
Sam E. Edmonson  
Chairman

  
\_\_\_\_\_  
Robert M. Davis  
Vice Chairman

  
\_\_\_\_\_  
Sean N. Williams  
Commissioner

ATTEST:

---

Executive Director